

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Temperature Sensor**with type designation(s)
W09, W14, W17, W20, T09, T14, T17, T20

Issued to

SIKA Dr. Siebert & Kühn GmbH & Co. KG
Kaufungen, Hessen, Germany

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft**Application :****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.****Temperature B****Humidity B****Vibration B****EMC N/A****Enclosure Required protection according to DNVGL Rules shall be provided upon installation on board**Issued at **Hamburg** on **2019-11-12**This Certificate is valid until **2024-10-21**.for **DNV GL**DNV GL local station: **Magdeburg**Approval Engineer: **Holger Jansen****Joannis Papanuskas**
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Product description

SIKA Temperature Sensors

W09, W14, W17, W20, T09, T14, T17, T20

Measuring range: 0°C up to 650°C
Measuring insert: 1xPt 100 3-wire
2xPt 100 3-wire
1xPt 100 4-wire
1xPt1000 2-wire
2xPt 1000 2-wire
Fe-CuNi, NiCr-Ni
Class B

Material protection tube: 1.4571, 1.4713 and special materials
Thread connection: G1/2, G3/4, M27x2, M33x2 and special threads

Application/Limitation

When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL RU SHIP Pt.4 Ch.9 Sec. 1.

Type Approval documentation

Tests carried out

Applicable tests according to Class Guideline DNVGL-CG-0339, Edition November 2016.
Extreme vibration strain with acceleration = 10g
(W153P312252B03NS, W203P54200238319)

Marking of product

The product to be market with:

- manufacturer name

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE